

CORRIGENDUM

Date-12-09-2024

With reference to the Minutes of Meeting held on 12-09-2024 at EMRI GHS, GOA related to tender no-EMRI GHS/GOA/02/SCM/2024-25 dated on 06-09-2024, named as “Short Term Tender notice for Procurement of Diesel Generator at EMRI GHS , Goa “

The following modifications/clarifications may be take note of prior to submission of bids by the prospective bidders.

Sr.No.	Reference	Query raised by vendor	Tender committee decision
1	Page no 5 , Pt.no. 13),	Requested to have only PBG instead of EMD & PBG	No change , both EMD & PBG procedural is mandatory
2	Page no 14 ANNEXURE-1, pt.no. A),1)	Requested to clarify on 24 V or 12V	12V starting system & not 24V
3	Page no 12, pt.no. 51)	Requested to have payment term as 90% advance & balance 10% against work completion	50% advance , 25% against material delivery & balance 25% against work completion or installation
4	Page no 13 ANNEXURE 1 :	Requested to clarify on installation cost	Explained Installation cost with bifurcation of 1) Civil foundation work 2) Earthing work 3) Power cable 4) RIO with Electricity dept. 5) Apart form above if anything please declare the same
5	Page no 5 , Pt.no. 13),	Requested to clarify on EMD amount as Installation cost will be variable	Instructed as per below : a) EMD will be applicable on Annexure 1), Sr.no. 1 & 2 (Diesel generator cost & AMF panel cost) b) Sr.no. 3 (Installation cost) may be variable cost & if its variable cost then can be excluded form EMD amount calculations. However if any vendor declaring this as fixed cost , EMD will be applicable on the same.

Note: Bidder need to submit the corrigendum document along with tender document with signature and stamp as token of acceptance of modifications/ clarifications.

Sd/

**EMRI Green Health
Services -GOA**